

排ガス濃度連続測定記録

平成 27年度

単位 (ppm)

日	1月								2月								3月							
	1号炉				2号炉				1号炉				2号炉				1号炉				2号炉			
	CO	Nox	SO ₂	HCL	CO	Nox	SO ₂	HCL	CO	Nox	SO ₂	HCL	CO	Nox	SO ₂	HCL	CO	Nox	SO ₂	HCL	CO	Nox	SO ₂	HCL
1													0	91	24	93	0	65	9	67	0	92	20	67
2													0	93	25	87	0	69	7	56	0	87	20	66
3													0	97	23	73	0	77	11	69				
4													0	96	24	87	1	78	9	59				
5	1	78	5	46	0	90	26	75					0	90	20	89								
6	0	82	3	27	0	90	26	65					0	101	26	75								
7	0	82	2	16	0	87	23	68					0	108	20	71								
8	1	87	5	34	0	107	27	87					0	96	22	72								
9	1	91	3	31	0	96	30	76					0	97	20	83								
10	0	87	2	20	0	94	28	70					0	95	25	92								
11	0	85	2	18	0	91	25	69					0	90	24	73								
12	2	86	2	21	0	93	26	71					0	91	21	84								
13	0	85	3	20	0	91	25	70					0	99	36	79	0	70	13	34				
14	1	85	3	29	0	96	26	73					0	96	32	70	1	79	10	49				
15	0	86	6	42	0	92	24	85					0	92	23	78	0	81	9	58				
16					0	96	21	69					0	90	20	79	0	86	13	53	0	89	22	59
17					0	95	23	86					0	95	23	84	0	92	9	50	0	95	21	73
18					0	101	24	81					0	92	26	85	0	85	12	64	0	96	26	84
19					0	90	18	76					0	90	29	100	0	88	13	54	0	96	27	68
20					0	96	21	74					0	93	26	88	0	88	14	61	0	97	23	79
21					0	90	11	53					0	95	26	120	0	90	12	54	0	95	23	79
22					0	93	19	92					0	96	24	76	1	85	12	54	0	97	21	71
23					0	102	19	103					0	103	31	107	1	89	13	51	0	98	25	69
24					0	95	15	72					0	93	25	77	3	87	11	44	0	98	17	62
25					0	88	12	61					0	98	27	77	1	85	12	61	0	100	17	76
26					0	93	12	62					0	95	25	97	1	87	9	39	0	93	15	62
27					0	80	22	69					0	100	26	70	0	91	6	29	0	100	14	70
28					0	94	20	70					0	91	27	70	0	94	5	27				
29					0	97	29	122	1	68	10	59	0	97	30	76	0	95	9	46				
30					0	94	20	71									0	98	7	37				
31					0	91	18	73									0	93	3	30				